



DANIEL P. McCOY  
County Executive

**DEPARTMENT OF HEALTH**  
COUNTY OF ALBANY  
175 GREEN STREET  
ALBANY, NEW YORK 12202

*The Dr. John J.A. Lyons*  
ALBANY COUNTY HEALTH FACILITY  
(518) 447-4580 FAX (518) 447-4698  
[www.albanycounty.com](http://www.albanycounty.com)

MARIBETH MILLER, BSN, MS  
Interim Commissioner for Public Health

RANSOM MOORE III  
Assistant Commissioner Finance and Administration

February 21, 2025

McNulty-Ryan, Eileen  
Village of Green Island  
20 Clinton Street  
Village of Green Island, NY 12183

Re: GREEN ISLAND VILLAGE  
NY0100195  
Notice of Violation No. 2025 372

Dear Mrs. McNulty-Ryan,

These Notice of Violation (NOV) is a result of monthly samples collected during the monitoring period of 10/01/2024 and 12/31/2024. The running annual average (RAA) compliance ratio for the fourth quarter of 2023 is less than 1.00; the system is not in compliance with the TOC percent removal requirements.

You are required to notify the public within 30 days of receiving this Notice of Violation. The public notification certification form must be completed and returned to this office within 10 days of completion of public notification along with a copy of the distributed notice. Community water systems must include this violation in their 2024 Annual Water Quality Report.

If you have any questions, do not hesitate to contact the Albany County Department of Health at (518) – 447 – 4620.

Sincerely,

Maxwell Ferris, P.E.  
Director  
Division of Environmental Health Services



**Albany County Department of Health** is nationally accredited and meets rigorous public health standards set forth to best meet the needs of our community.